



# CITY OF BRISTOL TENNESSEE

801 Anderson Street  
P.O. Box 1189  
Bristol, Tennessee 37621-1189

Public Works Department

Telephone: (423) 989-5677  
Facsimile: (423) 989-5632  
Email: [fneal@bristoltn.org](mailto:fneal@bristoltn.org)

May 31, 2017

Mr. Dane Cutshaw  
Tennessee Department of Environment and Conservation  
Division of Water Pollution Control  
2305 Silverdale Road  
Johnson City, Tennessee 37601-2162

Dear Mr. Cutshaw:

This letter is to officially notify you of the discharge of untreated sanitary sewage from the City of Bristol Tennessee collection, NPDES Permit No. TN0023531. This discharge was reported to you by phone (voice mail) on Tuesday, May 30, 2017 at approximately 11:30 a.m. The particulars are as follows:

Location: 1329 Valley Drive, Bristol, Tennessee  
Discovered/Reported: Thursday, May 25, 2017 at approximately 1:00 p.m.  
Cause: Wet Weather

Comments: City was contacted regarding a sanitary sewer manhole discharging during a very significant rain event beginning Thursday, May 25, 2017 through Friday May 26, 2017. City crews reported immediately checking manholes in area for possible obstructions and found manhole at 1329 Valley Drive surcharging due to significant rainfall. The main was observed flowing without hindrance once rain event passed and crews cleaned, disinfected and deodorized the discharge area. Sewer main is 10-inch line. The amount of the discharge is unknown. The City of Bristol Tennessee is currently active in seeking and correcting inflow and infiltration in the city sanitary sewer system.

If you have any questions regarding this event, please do not hesitate to contact me at (423) 989-5262 or (423) 989-5677.

Sincerely,

Frank Neal  
Superintendent of Maintenance

c: Timothy H. Beavers, Public Works Director  
Matthew Dake, Severn Trent, WWTP  
TDEC File



## CITY OF BRISTOL TENNESSEE

801 Anderson Street  
P.O. Box 1189  
Bristol, Tennessee 37621-1189

Public Works Department

Telephone: (423) 989-5677  
Facsimile: (423) 989-5632  
Email: [fneal@bristoltn.org](mailto:fneal@bristoltn.org)

May 31, 2017

Mr. Dane Cutshaw  
Tennessee Department of Environment and Conservation  
Division of Water Pollution Control  
2305 Silverdale Road  
Johnson City, Tennessee 37601-2162

Dear Mr. Cutshaw:

This letter is to officially notify you of the discharge of untreated sanitary sewage from the City of Bristol Tennessee collection, NPDES Permit No. TN0023531. This discharge was reported to you by phone (voice mail) on Tuesday, May 30, 2017 at approximately 11:30 a.m. The particulars are as follows:

Location: 234 Edgewood Drive, Bristol, Tennessee  
Discovered/Reported: Thursday, May 25, 2017 at approximately 1:00 p.m.  
Cause: Wet Weather

Comments: City was contacted regarding a sanitary sewer manhole discharging during a very significant rain event beginning Thursday, May 25, 2017 through Friday May 26, 2017. City crews reported immediately checking manholes in area for possible obstructions and found manhole at 234 Edgewood Drive surcharging due to significant rainfall. The main was observed flowing without hindrance once rain event passed and crews cleaned, disinfected and deodorized the discharge area. Sewer main is 10-inch line. The amount of the discharge is unknown. The City of Bristol Tennessee is currently active in seeking and correcting inflow and infiltration in the city sanitary sewer system.

If you have any questions regarding this event, please do not hesitate to contact me at (423) 989-5262 or (423) 989-5677.

Sincerely,

Frank Neal

Superintendent of Maintenance

c: Timothy H. Beavers, Public Works Director  
Matthew Dake, Severn Trent, WWTP  
TDEC File



# CITY OF BRISTOL TENNESSEE

801 Anderson Street  
P.O. Box 1189  
Bristol, Tennessee 37621-1189

Public Works Department

Telephone: (423) 989-5677  
Facsimile: (423) 989-5632  
Email: [fneal@bristoltn.org](mailto:fneal@bristoltn.org)

May 31, 2017

Mr. Dane Cutshaw  
Tennessee Department of Environment and Conservation  
Division of Water Pollution Control  
2305 Silverdale Road  
Johnson City, Tennessee 37601-2162

Dear Mr. Cutshaw:

This letter is to officially notify you of the discharge of untreated sanitary sewage from the City of Bristol Tennessee collection, NPDES Permit No. TN0023531. This discharge was reported to you by phone (voice mail) on Tuesday, May 30, 2017 at approximately 11:30 a.m. The particulars are as follows:

Location: 440 Gentry Lane, Bristol, Tennessee  
Discovered/Reported: Thursday, May 25, 2017 at approximately 1:00 p.m.  
Cause: Wet Weather

Comments: City was contacted regarding a sanitary sewer manhole discharging during a very significant rain event beginning Thursday, May 25, 2017 through Friday May 26, 2017. City crews reported immediately checking manholes in area for possible obstructions and found manhole on Cedar Creek trunk line surcharging due to significant rainfall. The main was observed flowing without hindrance once rain event passed and crews cleaned, disinfected and deodorized the discharge area. Sewer main is 8-inch line. The amount of the discharge is unknown. The City of Bristol Tennessee is currently active in seeking and correcting inflow and infiltration in the city sanitary sewer system.

If you have any questions regarding this event, please do not hesitate to contact me at (423) 989-5262 or (423) 989-5677.

Sincerely,

Frank Neal  
Superintendent of Maintenance

c: Timothy H. Beavers, Public Works Director  
Matthew Dake, Severn Trent, WWTP  
TDEC File



## CITY OF BRISTOL TENNESSEE

801 Anderson Street  
P.O. Box 1189  
Bristol, Tennessee 37621-1189

Public Works Department

Telephone: (423) 989-5677  
Facsimile: (423) 989-5632  
Email: [fneal@bristoltn.org](mailto:fneal@bristoltn.org)

May 31, 2017

Mr. Dane Cutshaw  
Tennessee Department of Environment and Conservation  
Division of Water Pollution Control  
2305 Silverdale Road  
Johnson City, Tennessee 37601-2162

Dear Mr. Cutshaw:


This letter is to officially notify you of the discharge of untreated sanitary sewage from the City of Bristol Tennessee collection, NPDES Permit No. TN0023531. This discharge was reported to you by phone (voice mail) on Tuesday, May 30, 2017 at approximately 11:30 a.m. The particulars are as follows:

Location: 730 Oakwood Road, Bristol, Tennessee  
Discovered/Reported: Thursday, May 25, 2017 at approximately 1:00 p.m.  
Cause: Wet Weather

Comments: City was contacted regarding a sanitary sewer manhole discharging during a very significant rain event beginning Thursday, May 25, 2017 through Friday May 26, 2017. City crews reported immediately checking manholes in area for possible obstructions and found manhole at 730 Oakwood Road surcharging due to significant rainfall. The main was observed flowing without hindrance once rain event passed and crews cleaned, disinfected and deodorized the discharge area. Sewer main is 8-inch line. The amount of the discharge is unknown. The City of Bristol Tennessee is currently active in seeking and correcting inflow and infiltration in the city sanitary sewer system.

If you have any questions regarding this event, please do not hesitate to contact me at (423) 989-5262 or (423) 989-5677.

Sincerely,

  
Frank Neal  
Superintendent of Maintenance

c: Timothy H. Beavers, Public Works Director  
Matthew Duke, Severn Trent, WWTP  
TDEC File